



Certificate of Compliance

This certificate is issued for the following:

Centrifugal Fire Pumps (Axial Split-Case Type)

YPSP 65-250, YPSP 80-250 and YPSP 100-250
(see attached listing)

Prepared for:

MAS DAF Makina Sanayi A S
Aydinli Mah Birlik O S B 1
Cad No 1 Tuzla
Istanbul, Turkey

FM Approvals Class: 1311 (January 2018)

Approval Identification: PR452131

Approval Granted: September 17, 2019

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Product	Rated Capacity, (gal/min)	Rated Capacity, (dm ³ /min)	Rated Net Head at Rated Capacity, psi	Rated Net Head at Rated Capacity, kPa	Rated Speed, r/min	Suction Inlet, dia., in.	Discharge Outlet, dia., in.	Stage(s)
YPSP 65-250	250	1515	78-131	540-905	2950	4	2.5	1
YPSP 65-250	300	1135	75-130	515-895	2950	4	2.5	1
YPSP 80-250	300	1135	102-165	705-1140	2950	5	3	1
YPSP 80-250	400	1515	101-163	695-1125	2950	5	3	1
YPSP 80-250	450	1705	99-163	685-1125	2950	5	3	1
YPSP 80-250	500	1895	98-162	675-1115	2950	5	3	1
YPSP 100-250	500	1895	92-171	635-1180	2950	6	4	1
YPSP 100-250	750	2840	86-169	595-1165	2950	6	4	1
YPSP 100-250	1000	3785	80-168	550-1160	2950	6	4	1



Member of the FM Global Group